

**ADDENDUM 5 DATED 17/07/ 2023**

**Tender ID: 2023\_IITS\_758376\_1**

**Tender Reference: IITS\_NIT\_011\_2023**

**NIT: Interior works – Design, Supply, and installation, Testing and Commissioning of CCTV and Wi Fi System in newly constructed Boys Hostel 3, 4 and Dining block of Indian Institute of Information Technology Sri City, Chittoor as per the standard Specification**

<b>Sl No</b>	<b>Queries</b>	<b>IIT Sri City Clarifications</b>
1	Dome camera with varifocal lens for Monitoring the corridors. Whereas, in corrigendum it has been simply mentioned as 2 MP Dome cameras. We wish to inform you that the varifocal camera with 2.8 to 12 mm lens is extravagant and expensive for Corridor monitoring. Alternatively, 2.8 mm fixed lens Dome camera is adequate and cost effective for IIT Corridor monitoring requirements in hostels.	The CCTV Camera specification is 2MP Dome cameras (Hikvision and CP Plus). The Varifocal Length cameras are NOT required