

Indian Institute of Information Technology Sri City, Chittoor

(An Institute of National Importance under an Act of Parliament)

CORRIGENDUM 5

Tender ID: 2025_IITS_846154_1, Dt. 25.01.2025

Tender Reference No.: IIITS_NIT_029_2025

Name of the Work: Civil, PHE, Fire Fighting, Electrical and associated External Development Works for the Construction of Academic Block (AB2) with B+G+2 floors as RCC framed structure and Boys Hostel Block (BH5) with G+10 floors as shear wall structure at IIIT Sri City Campus.

Corrigendum Details: The following modification were made in the e-Tender.

S. No.	As per NIT Document	Modification
	•	
1	General Conditions of Contract Clause 6,	The Input Tax Credit (ITC)
	Page 27	condition or conditions listed in the
	Taxes, Duties etc.,	tender have been removed from all
	The GST paid on purchase of Materials	applicable clauses.
	shall be transferred as "Input Tax	
	Credit" to the IIIT Sri City, Chittoor by	
	the contractor	
2	BoQ1	These items are removed from the
	Academic Block [AB2] – Electrical Works	scope of work together with relevant
		items like wiring, panels etc.,
	Item No. 229: UPS OUTPUT PANEL	elsewhere mentioned in the BoQ.
	(EL)	
	Item No. 230: UPS OUTPUT PANEL	Bidder may quote ZERO RUPEES
	WS-1	at the designated items rate column.
	Item No. 231: UPS OUTPUT PANEL	Those who have already submitted
	WS-1	their bid, the cost for these items
		will be deducted for evaluation
	Item No. 237: UPS & Batteries for	purpose.
	Emergency Lighting	
	Item No. 237.1 – 300KVA 3ph/3ph,	
	Battery Bank suitable for the UPS to	
	provide 20 Min Back up	
	Item No. 237.2 – 15KVA 3ph/3ph, Battery	
	Bank suitable for the UPS to provide 90	
	Min Back up	



Indian Institute of Information Technology Sri City, Chittoor

(An Institute of National Importance under an Act of Parliament)

S. No.	As per NIT Document	Modification
3	BoQ2	These items are removed from the
	Boys Hostel [BH5] – Electrical Works	scope of work together with relevant
		items like wiring, panels etc.,
	Item No. 224: UPS OUTPUT PANEL	elsewhere mentioned in the BoQ.
	Item No. 230: UPS & Batteries for	Bidder may quote ZERO RUPEES
	Emergency Lighting	at the designated items rate column.
		Those who have already submitted
	Item No. 230.1 – 15KVA 3ph/3ph, Battery	their bid, the cost for these items
	Bank suitable for the UPS to provide 90	will be deducted for evaluation
	Min Back up	purpose.

Note:

- a. These modifications shall form the part of bid document/Agreement.
- b. Rest of the terms and conditions and specifications of the bid document shall continue to remain same.
- c. The above amendments/ clarifications are issued for the information for all the intending bidders.
- d. The submission of bid by the firm shall be construed to be in conformity to the bid document and amendments/ clarifications given above.